

Our Ref : 12/2020-
Date :

Messrs:

Dear Sir,

Tender 12/2020
Heat Shrinkable Joints, Terminations and Connectors

You are kindly requested to quote for the supply and delivery of *Medium and Low Voltage Underground cable accessories* in the attached specifications and schedules **D.D.P** to our stores in Shufat.

IEC recommendation for workmanship, equipment and materials has been selected in this specifications as a base of reference standards and specifications of other countries.

Our company does not bind itself to accept the lowest or any tender nor to assign any reason for the rejection of any tender, nor to purchase the whole of the equipment and materials specified.

All correspondences in connection with this tender and all matters accompanying the tender who is relevant to its examinations shall be in English language and expressed in metric units.

Essential Bidding Requirements:

- A bank certified check or a bank guarantee of 5% of the total tender valid for 90 days, to be submitted as a bid bond, otherwise, quotation will be neglected.
- Quotation should be enclosed in a sealed envelope or package and handed over to the "Tender Committee" by the representative of the bidder or their agent not later than 31.3.2020 at 11:00 AM.
- TENDER DOCUMENTS FEES: 500 US\$. A proof of payment should be sent by email to : rnashashibi@jdeco.net.
- The main offer envelope or package should include three separate envelopes as follow:
 - a. The financial offer in a separate sealed envelope.
 - b. The technical offer & catalogues placed in a separate sealed envelope.
 - c. Your bid bond in a separate envelope.
- Technical offer will be studied separately from the financial offer. The financial offers for bidders whose technical offers do not meet JDECO's technical requirements will not be opened.
- In case offers are submitted by an agent on behalf of a certain supplier, a copy of the agreement between the agent and the supplier must also be submitted.

Such copy has to be authenticated and certified by the chamber of commerce at the supplier's country of origin.

- Offers have to be attached with a letter confirming the authorized persons signing on behalf of the bidder.

Any bid package not according to the above will not be considered.

Payment method in case of offer acceptance:

- 90 days after delivery of goods through bank transfers.
- The currency of the suppliers' invoices must be the same as the currency of their submitted offer and as specified in the letter of award, otherwise they will not be accepted.

Notes:

- The company has the liberty not to accept any or the lowest tender neither to assign any reason for rejection of any tender.
- The accepted bidder will be charged the expenses of the tender's advertisement in the local newspapers.
- Upon acceptance of offer the bidder will be requested to submit a Performance Bond equivalent to 10% of the tender total value, and should be valid for ...30..... working days from the date of executing all terms of contract.

Yours faithfully

Hisham Omari
Chairman of Directors' Board
& Managing Director

1. Bill of quantities:

Item 1	For medium voltage 42Kv single core underground cable with cross section (150-240)mm ² Similar to the type NA2XS(F)2Y & N2XS(F)2Y	Unit	Quantity
a.	Complete straight joint with Tin plated Head shear off screws Sleeve, suitable for copper and aluminum conductors.	Pcs	2000
b.	Sets of outdoor terminations with Tin plated Head shear off screws Cable Lug, suitable for copper and aluminum conductors.	Set	500

Item 2	For medium voltage 42Kv single core underground cable with cross section (400)mm ² Similar to the type NA2XS(F)2Y & N2XS(F)2Y	Unit	Quantity
a.	Complete joint with Tin plated Head shear off screws Sleeve, suitable for copper and aluminum conductors.	Pcs	100
b.	Sets of outdoor terminations with Tin plated Head shear off screws Cable Lug, suitable for copper and aluminum conductors.	Set	100
c.	Sets of indoor terminations with Tin plated Head shear off screws Cable Lug, suitable for copper and aluminum conductors.	Set	50

Item 3	sets of cold applied insulating boot up to 17.5KV similar to the type RCAB-4120 Raychem	Unit	Quantity
a.	Each set contains 3 pcs suitable for Three Core Cable: N2XSEY 3*(50-120mm2)].	set	100

Item 4	Breakouts for multi core low voltage cables up to 1KV similar to N2XY & NA2XY cables.	Unit	Quantity
a.	Breakouts for cables up to 4x(150-240)mm ² NA2XY.	Pcs	2000
b.	Breakouts for cables up to 4x(35-50)mm ² N2XY	Pcs	1000
c.	Breakouts for cables up to 4x16mm ² N2XY	Pcs	1000
d.	Breakouts for cables up to 3x10mm ² N2XY	Pcs	10000

Item 5	Heat shrinkable joints for multi core low voltage cables up to 1KV similar to N2XY & NA2XY cables.	Unit	Quantity
a.	Complete joints for cables up to 4x(120-240)mm ² .	set	100
b.	Complete joints for cables up to 4x(35-70)mm ² .	set	100
c.	Complete joints for cables up to 4x(16-35)mm ² .	set	300

Item 6	Heat shrinkable end cap for protection against moisture and pressure for single core and multi core cables as following:	Unit	Quantity
a.	Diameter 35/15	Pcs	300
b.	Diameter 55/25	Pcs	300
c.	Diameter 73/30	Pcs	300
d.	Diameter 95/40	Pcs	300

2. Payment method:

- 90 days after delivery of goods through bank transfers.
- The currency of the suppliers' invoices must be the same as the currency of their submitted offer and as specified in the letter of award, otherwise they will not be accepted.

-

3. Shipment:

- Shipment of goods should be supplied to our stores in Shufat-Jerusalem.
- Shipment should be as soon as possible.